

Legionnaires Disease risk assessment and guidelines

1) Who can carry out an assessment?

Hosts and Operators can carry out a Legionnaire's risk assessment themselves if the property is a single dwelling or a flat with its own water supply (hot and cold) and they are competent to do so. In particular you should:

- understand different types of water systems;
- understand Legionella bacteria and the factors which increase the risk of an outbreak in a domestic setting;
- understand the control measures which if present will reduce the risk of an outbreak; within a domestic setting.

Before considering carrying out a risk assessment you should familiarise yourself in particular with the following HSE publications: -

Legionnaire's disease: A brief guide for duty holders - <http://www.hse.gov.uk/pubns/indg458.pdf>

Legionnaire's disease Part 2: The control of legionella bacteria in hot and cold water systems - <https://www.hse.gov.uk/pubns/priced/hsg274part2.pdf>

If you do not consider that you are competent to carry out a risk assessment, then you could contact your local plumber who will be able to assist.

2) The risk assessment process

The practical risk assessment should include a site survey of the water system. A template is attached which is suitable for a basic system and can be adapted as required. The assessor should complete all the sections coloured blue.

The assessor should understand the water systems and any associated equipment in the property, in order to conclude whether the system is likely to create a risk from exposure to Legionella.

It is important to identify whether:

- water is stored or re-circulated as part of the system (areas of risk include water tanks, dead legs, shower heads and/or long runs of pipe work containing warm water);
- the water temperature in some or all parts of the system is between 20 – 45°C (hot water should be stored in any tanks at 60°C);

- there are sources of nutrients such as rust, sludge, scale and organic matters;
- conditions are present to encourage bacteria to multiply;
- it is possible for water droplets to be produced and, if so, whether they could be dispersed, e.g. showers;
- there are parts of the system that are used infrequently e.g. guest bathrooms;

Reviewing the risk assessment

If the risk assessment concludes there is no reasonably foreseeable risk or the risks are insignificant and are managed properly to comply with the law, the assessment is complete. Although no further action may be required at this stage, existing controls must be maintained. The assessment of risk is an ongoing process and not merely a paper exercise. The assessment should be reviewed regularly and specifically when there is reason to suspect it is no longer valid.

Guests

Hosts and Operators should inform guests of the following:-

- inform the host/operator if they believe the hot water temperature is below 50°C or the hot water tank/boiler is defective in any way;
- not to adjust the temperature of the hot water;
- advise the Host/Operator if they believe the cold-water temperature is above 20°C;
- notify the Host/Operator if they notice any debris or discolouration in the hot or cold water.

Legionnaires Disease Risk Assessment

premise address	BRIMPTON VILLAGE HALL, CROOKHAM COMMON ROAD, BRIMPTON, RG7 4ST
Date of assessment	26/07/24
Assessment carried out by	JOHN DOLPHIN

Describe property type	SINGLE STOREY RURAL VILLAGE HALL
Describe type of cold-water system e.g. mains feed or from storage tank	MAINSFEED
Describe type of hot water system e.g. mains feed via combi boiler or from storage tank.	MAINSFEED FROM INSTANT ELECTRICAL WATER HEATER

Risk categories

Water outlet temperature

Is cold water temperature at outlets below 20°C?	Yes/No	16.7-18.5
Is the hot water temperature above 50°C at outlets?	Yes/No	50.6-59.1

Cold water must flow from outlets at below 20°C and hot water above 50°C to minimise risk. If temperatures are too low/high then adjustments need to be made to the system such as lagging of pipework or adjustment of temperature settings for hot water.

Identify any defect/risks and related recommendations associated with water outlet temperature. If any action is required identify responsible person: -

Defect/Risk	IF COLD WATER ABOVE 20°C
Recommendation	RUN WATER FOR 30sec's TO REDUCE WATER TEMPERATURE.
Responsible person: Host/Operator/other	OPERATOR

Cold water storage tanks

Is there one present?	Yes/No	
Location		N/A
Does it have a tight fitting lid?	Yes/No	N/A
Is the water in the tank clean and free from rust, debris, scale and organic matter?	Yes/No	N/A
Is the temperature of the water in the tank below 20°C?	Yes/No	N/A
Is the tank insulated?	Yes/No	N/A

If any debris etc. is present in the system, it should be drained and thoroughly cleaned. If debris is from corrosion on the tank itself, then the tank may need to be replaced. All cold water tanks should have tight fitting lids to prevent debris entering the system. The water in the tank should be below 20°C and the tank should be insulated to prevent the temperature rising above this level.

Identify any defect/risk and related recommendations associated with cold water storage. If any action is required identify responsible person: -

Defect/Risk	N/A AS NONE PRESENT
Recommendation	
Responsible person: Host/Operator/other	

3 Hot water

Is the temperature setting on the boiler and/or hot water tank such that the hot water is heated to and stored at a temperature of 60°C?	Yes/No	
--	--------	--

NB: If the temperature is set at above 60°C this can cause scalding to users.

The temperature setting on the boiler and/or hot water tank should be set and maintained at 60°C.

Identify any defect/risk and related recommendations associated with hot water. If any action is required identify responsible person: -

Defect/Risk	IF WATER ABOVE 60°C
Recommendation	CHANGE SETTING ON WATER HEATER
Responsible person: Host/Operator/other	HOST BRIMPTON VH TRUSTEES

4 Little used outlets

Are there any water outlets that are used less than once per week?	Yes/No? If yes, identify outlet & location FRONT TABLE STORE ROOM
--	--

Any little used outlets should be flushed through weekly by running water through the outlet for at least 2 minutes. Aerosol production should be minimised during this process.

Identify any risks and related recommendations associated with little used outlets. If any action is required identify responsible person: -

Defect/Risk	STAGNANT WATER
Recommendation	RUN TAP IN SINK FOR 2mins ONCE A WEEK
Responsible person: Host/Operator/other	BRIMPTON VH TRUSTEES

5 Shower heads

Are there any showers in the property?	Yes /No?	If yes, identify location
		N/A

All shower heads should be cleaned, disinfected and descaled at least once every 6 months. Aerosol production should be minimised during this process.

Identify any risks and related recommendations associated with shower heads. If any action is required identify responsible person: -

Defect/Risk	N/A AS NONE PRESENT
Recommendation	
Responsible person: Host/Operator/other	

6 Dead legs and redundant pipework

Sections of pipework which are redundant or owing to the system design and have little/no through flow of water (known as “dead legs”) can allow water to stagnate in the system. Are there any dead legs known in the system? If so, please describe.

Are there any dead legs in the property?	Yes /No?	If yes, identify location:
		N/A

Any dead legs in pipework should be removed or the system altered so that water flows through all pipework on a regular basis.

Identify any risks and related recommendations associated with dead legs. If any action is required identify responsible person: -

Defect/Risk	N/A AS NONE PRESENT
Recommendation	
Responsible person: Host/Operator /other	

7 Unoccupied properties

Is the property left unoccupied for periods of time, e.g. no bookings at certain times of the year e.g. Christmas/New Year?	Yes /No	
---	--------------------	--

During periods of inoccupancy all outlets on hot and cold water systems should be flushed through at least once a week for at least 2 minutes. For long periods consider draining the system. Make sure that the system is flushed through when it is re-occupied by running all outlets for at least 2 minutes. Aerosol production should be minimised during this process.

Identify any risks and related recommendations associated with inoccupancy. If any action is required identify responsible person: -

Defect/Risk	N/A AS HALL IS USE ALL YEAR ROUND
Recommendation	
Responsible person: Host/Operator/other	

8 Advice to Guests

Has advice been given to guests as to the risks of Legionnaires Disease in a domestic setting and their responsibilities to minimise risk?	Yes/No	INFO ON WEBSITE
--	--------	-----------------

This can be done by providing the guests with an advice sheet raising the points noted under the section 2 of this document.

The assessment is complete and should be reviewed regularly (at least once a year) and specifically when there is reason to suspect it is no longer valid. You should ensure that the recommendations above are implemented and any existing controls maintained.

**Legionnaire's Disease Risk Assessment review
(1ST ONE DUE JULY 2025)**

To be completed at least once per year.

Premise address	
Date of assessment	
Assessment carried out by	

If any of the following are true, please tick the box on the right.

Since the original risk assessment was carried out: -

Has there been a change to the water system or the way it is used by guests?

Has there been a change to the use of the building where the system is installed?

Is there new information available about risks or control measures?

When testing the temperature of the water in the system, does hot water flow from any outlets at a temperature of below 50C?

When testing the temperature of water in the system, does cold water flow from any outlets at a temperature of above 20C?

Has there been a case of Legionnaires Disease associated with the system?

If you have ticked in response to any of the questions above, a new risk assessment should be carried out by a competent person.